


The Bayfordbury SLC Fire Plan



* If alarm activation is obviously false e.g. burnt food, accidental MCP use, Fire Marshal can call the Securitas monitoring station to enable the Fire Brigade to be stood down. Fire Marshal must check the fire panel for activation location to ensure a fire is not present in another part of the building before calling the monitoring station.